

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0100052	BETHLEHEM ELEMENTARY SCHOOL/DISTRICT 14			NTNC	406	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 EAST STREET				1				

Towns Served: BETHLEHEM

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per six months</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete
	1/1/19 - 6/30/19		Complete
	7/1/19 - 12/31/19		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: **ENTRY POINT - WELLS 1 & 2 (WSF ID: 00700)**

<b>Chloride (1017)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0100052	BETHLEHEM ELEMENTARY SCHOOL/DISTRICT 14			NTNC	406	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 EAST STREET			1				
Towns Served: BETHLEHEM							

### Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 1 & 2 (WSF ID: 00700)

**Pesticides, Herbicides and PCBs - Phase II & V (SOCs)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		

**Organic Chemicals (VOCS)** **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2020	

### Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Chloride MCL Violation	10/1/18 - 12/31/18	2	3/23/2019	2/25/2019	4/2/2019	2/28/2019
Chloride MCL Violation	1/1/19 - 3/31/19	2	5/9/2019		5/19/2019	

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	14BETH001	CAFETERIA	A	Y	2	Y	
		14BETH001 -	GENERATED BY BATCH	A	Y			
		14BETH002	NURSE	A	Y	2	Y	
		14BETH002 -	GENERATED BY BATCH	A	Y			
		14BETH003	STAFF BATH	A	Y	2	Y	
		14BETH003 -	GENERATED BY BATCH	A	Y			
		14BETH004	K-BOYS BATH	A	Y	2	Y	
		14BETH004 -	GENERATED BY BATCH	A	Y			
		14BETH005	K GIRLS BATH	A	Y	2	Y	
		14BETH005 -	GENERATED BY BATCH	A	Y			
		14BETH006	1ST GRADE GIRLS	A		2	Y	
		14BETH006 -	GENERATED BY BATCH	A	Y			
		14BETH007	1ST GRADE BOYS	A	Y	2	Y	
		14BETH007 -	GENERATED BY BATCH	A	Y			
		14BETH008	GYM BATH	A	Y	2	Y	
		14BETH008 -	GENERATED BY BATCH	A	Y			
		14BETH009	ART ROOM LOWER LEV	A	Y	2	Y	
		14BETH009 -	GENERATED BY BATCH	A	Y			
		14BETH010	GARAGE SINK	A	Y	2	Y	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0100052	BETHLEHEM ELEMENTARY SCHOOL/DISTRICT 14			NTNC	406	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 EAST STREET			1				
Towns Served: BETHLEHEM							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		14BETH010 -	GENERATED BY BATCH	A	Y			
		14BETH011	OFFICE 2	A	Y	2	Y	
		14BETH012	GIRLS 2 BATH	A	Y	2	Y	
		14BETH013	BOY'S 2 BATH	A	Y	2	Y	
		14BETH014	CLASS 106	A	Y	2	Y	
		14BETH015	OFFICE 121	A	Y	2	Y	
		14BETH016	KITCHEN 2 SINK	A	Y	2	Y	
		14BETH017	CLASS 109	A	Y	2	Y	
		14BETH018	ART UPPER LEVEL	A	Y	2	Y	
		14BETH019	OFFICE 125	A	Y	2	Y	
		14BETH020	CLASS 112	A	Y	2	Y	
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - WELLS 1 & 2	3	ENTRY POINT	A				
10044	WELL 1	2	WELL 1	A				
60082	WELL 2	2	WELL 2	A				

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMAY, REALE D.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2019 6/30/2020
KILBOURN, ERIC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019 12/31/2019

### Contact Information

Name				Organization			Job Title		
Mr. Michael P. Molzon				Regional School District #14			Dir Buildings & Grnd		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
5 Minor Town Road			P.O. Box 469			Woodbury		CT	06798-0469
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-263-4330			203-263-0372		203-263-4330	mimolzon@ctreg14.org			
Contact Role(s): Administrative Contact, Legal Contact, Owner									

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0100052	BETHLEHEM ELEMENTARY SCHOOL/DISTRICT 14			NTNC	406	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 EAST STREET			1				
Towns Served: BETHLEHEM							

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

***NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0105023	THE WELLSRING FOUNDATION, INC.			NTNC	63	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
21 ARCH BRIDGE ROAD				3				

Towns Served: BETHLEHEM

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0105023	THE WELLSRING FOUNDATION, INC.			NTNC	63	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
21 ARCH BRIDGE ROAD			Connections	3				
Towns Served: BETHLEHEM								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2020	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WSFM001	MAIN KITCHEN SINK	A	Y	2	Y	
		WSFM002	KITCHEN REFRIG SINK	A	Y	2	Y	
		WSFM003	1ST FLOOR RESID BATH	A	Y	2	Y	
		WSFM004	2ND FLOOR BATH #1	A	Y	2	Y	
		WSFM005	2ND FLOOR BATH #7	A	Y	2	Y	
		WSFM006	1ST FLOOR STAFF BATH	A	Y	2	Y	
		WSFM007	LAUNDRY SINK	A	Y	2	Y	
00700	ENTRY POINT	3	ENTRY POINT	A				
10045	WELL	2	WELL	A				

### Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMAY, REALE D.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2019 6/30/2020
KILBOURN, ERIC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019 12/31/2019

### Contact Information

Name		Organization			Job Title	
Mr. William Bailey		Wellspring Foundation, Inc.			Maint. Supervisor	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
21 Arch Bridge Road		P.O. Box 370		Bethlehem	CT	06751
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-266-8000	8045	203-266-8030		860-841-8261	BILL.BAILEY@WELLSRING.ORG	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0105023</b>	<b>THE WELLSRING FOUNDATION, INC.</b>	<b>NTNC</b>	<b>63</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
21 ARCH BRIDGE ROAD		3			
Towns Served: BETHLEHEM					
Contact Role(s): <b>Administrative Contact</b>					
Name		Organization		Job Title	
<b>Ms. Luella Davis</b>		Wellspring LLC		Member	
Mailing Address Line One		Mailing Address Line Two		City	State
252 Main Street				Southport	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
Contact Role(s): <b>Legal Contact, Owner</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

***End of schedule***

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0100203	BETHLEHEM DAY CARE			NTNC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
185 MAIN STREET NORTH							1	

Towns Served: BETHLEHEM

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		
	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/18		Complete
	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0100203	BETHLEHEM DAY CARE			NTNC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
185 MAIN STREET NORTH						1	
Towns Served: BETHLEHEM							

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
CROSS CONNECTION EXEMPTION	3/1/2015	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		BETHDAY001	UPPER STAIRS BATHRM	A		2		
		BETHDAY002	YELLOW BATHROOM	A	Y	2		
		BETHDAY003	BACK DOOR FOUNTAIN	A		2		
		BETHDAY004	BLUE BATHROOM	A		2		
		BETHDAY005	KITCHEN	A		2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10825	WELL	2	WELL	A				
57345	UV DISINFECTION							

### Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: SMALL WATER SYSTEM			
Operator Name	Operator Type	Certification(s)	Certification Expiration
GRECO, VIRGINIA M.	CHIEF OPERATOR	SMALL WATER SYSTEM OPERATOR CONDITIONAL	12/31/2019
		SMALL WATER SYSTEM OPERATOR CONDITIONAL	12/31/2019

### Contact Information

Name				Organization			Job Title		
Ms. Virginia Greco							Owner/Director		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
185 Main Street North						Bethlehem		CT	06751
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-266-5159									
Contact Role(s):	Administrative Contact, Legal Contact, Owner								

**Please note the following:**

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0105053	WELLSPRING FOUNDATION - SHILOAH			NTNC	27	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
21 ARCH BRIDGE ROAD					2			

Towns Served: BETHLEHEM

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per six months</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete
	1/1/19 - 6/30/19		
	7/1/19 - 12/31/19		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0105053	WELLSPRING FOUNDATION - SHILOAH			NTNC	27	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
21 ARCH BRIDGE ROAD				2			
Towns Served: BETHLEHEM							

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2020	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WFSH001	#2 FLOOR BATH	A	Y	1	Y	
		WFSH002	#2 FLOOR HALL BATH	A	Y	1		
		WFSH003	#1 FLOOR BATH	A	Y	1		
		WFSH004	CLASSROOM BATH	A	Y	1		
		WFSH005	OUTSIDE TAP	I		1		
		WFSH006	KITCHEN	A	Y	1		
		WSFH005	GENERATED BY BATCH	I	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
52897	WELL	2	WELL	A				

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMAY, REALE D.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2020
KILBOURN, ERIC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019

### Contact Information

Name		Organization		Job Title		
Mr. William Bailey		Wellspring Foundation, Inc.		Maint. Supervisor		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
21 Arch Bridge Road		P.O. Box 370		Bethlehem	CT	06751
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-266-8000	8045	203-266-8030		860-841-8261	BILL.BAILEY@WELLSPRING.ORG	

Contact Role(s): **Administrative Contact**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0105053</b>	<b>WELLSPRING FOUNDATION - SHILOAH</b>	<b>NTNC</b>	<b>27</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
21 ARCH BRIDGE ROAD				2	
Towns Served: BETHLEHEM					
Name		Organization		Job Title	
<b>Mr. Herbert L. Hall</b>		Wellspring		Ceo	
Mailing Address Line One		Mailing Address Line Two		City	State
21 Arch Bridge Road				Bethlehem	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-266-8032					
Contact Role(s): <b>Legal Contact</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

***End of schedule***

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0105073	NEWPORT ACADEMY			NTNC	50	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
64 DOUBLE HILL ROAD					3			

Towns Served: BETHLEHEM

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/24		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per six months</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete
	1/1/19 - 6/30/19		Complete
	7/1/19 - 12/31/19		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAINTENANCE (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAINTENANCE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAINTENANCE (3)	1/1/17 - 12/31/19	1/1-12/31	Waiver
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAINTENANCE (3)	1/1/20 - 12/31/22		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MAINTENANCE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0105073	NEWPORT ACADEMY			NTNC	50	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
64 DOUBLE HILL ROAD					3			

Towns Served: BETHLEHEM

### Monitoring Requirements

Water System Facility: ENTRY POINT - MAINTENANCE (WSF ID: 00702)

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/20 - 12/31/20		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y	N	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		NPA 1 001	1 KITCHEN HANDWASH 1	I	Y	1	Y	
		NPA 1 002	1 KITCHEN HANDWASH 2	I	Y	1	Y	
		NPA 1 003	1 STAFF BATH SINK	I	Y	1	Y	
		NPA 1 004	ROOM 1 BATH SINK	I	Y	1	Y	
		NPA 1 005	ROOM 2 BATH SINK	I	Y	1	Y	
		NPA 1 006	ROOM 3 BATH SINK	I	Y	1	Y	
		NPA 1 007	ROOM 4 BATH SINK	I	Y	1	Y	
		NPA 1 008	ROOM 5 BATH SINK	I	Y	1	Y	
		NPA 1 009	OFFICE BATH SINK	I	Y	1	Y	
		NPA 2-3 001	KITCHEN SINK	I	Y	1	Y	
		NPA 2-3 002	ROOM 1 BATH SINK	I	Y	1	Y	
		NPA 2-3 003	ROOM 2 BATH SINK	I	Y	1	Y	
		NPA 2-3 004	ROOM 3 BATH SINK	I	Y	1	Y	
		NPA 2-3 005	ROOM 4 BATH SINK	I	Y	1	Y	
		NPA 2-3 006	ROOM 5 BATH SINK	I	Y	1	Y	
		NPA 2-3 007	OFFICE 4 BATH SINK	I	Y	1	Y	
		NPA 2-3 008	LAUNDRY BATH SINK	I	Y	1	Y	
		NPA001	KIT HANDWASH BLDG 4	A	Y	N	Y	
		NPA002	LOWER BATH 4 BLDG 4	A	Y	N	Y	
		NPA003	KIT HANDWASH BLDG 1	A	Y	N	Y	
		NPA004	KITCHEN BLDG 2	A	Y	N	Y	
		NPA005	LAUNDRY BATH BLDG 4	A	Y	N	Y	
		NPA006	LAUNDRY SINK BLDG 3	A	Y	N	Y	
		NPA007	LAUNDRY BATH BLDG 2	A	Y	N	Y	
		NPA008	ROTUNDA BATH BLDG 1	A	Y	N	Y	
		NPA009	DOCTOR BLDG 4	A	Y	N	Y	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0105073	NEWPORT ACADEMY			NTNC	50	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
64 DOUBLE HILL ROAD				3			
Towns Served: BETHLEHEM							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		NPA010	HVAC BATH BLDG 3	A	Y	N	Y	
		NPA011	BEDROOM 5 BLDG 2	A	Y	N	Y	
		NPA012	UPSTAIRS BATH BLDG 1	A	Y	N	Y	
		NPA013	DINING MENS BLDG 4	A	Y	N	Y	
		NPA014	DOCTOR BLDG 3	A	Y	N	Y	
		NPA015	BEDROOM 4 BLDG 2	A	Y	N	Y	
		NPA016	BEDROOM 1 BLDG 1	A	Y	N	Y	
		NPA017	BEDROOM 1 BLDG 4	A	Y	N	Y	
		NPA018	BEDROOM 1 BLDG 3	A	Y	N	Y	
		NPA019	BEDROOM 3 BLDG 2	A	Y	N	Y	
		NPA020	BEDROOM 2 BLDG 1	A	Y	N	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00702	ENTRY POINT - MAINTENANCE	3	EP-MAINTENANCE	A				
59632	WELL 1	2	WELL 1	A				
59667	WELL 2	2	WELL 2	A				
59669	WELL 3	2	WELL 3	A				
60107	WELL 4	2	WELL 4	A				
60110	ATMOSPHERIC TANK							
60112	BLADDER TANK							
60114	PUMP STATION							
60333	WELL 7	2	WELL 7	A				

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMAY, REALE D.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2019 6/30/2020
KILBOURN, ERIC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019 12/31/2019

### Contact Information

Name			Organization			Job Title	
Mr. Jamison Monroe			Health Real Estate Holdings			Ceo	
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
64 Double Hill Rd					Bethlehem	CT	06751
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
949-887-0242					jmonroe@newportacademy.com		

Contact Role(s): **Administrative Contact, Legal Contact**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0105073	NEWPORT ACADEMY			NTNC	50	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
64 DOUBLE HILL ROAD			3				
Towns Served: BETHLEHEM							

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

***NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.***